

Slip Check to AS 4586:2013

Quantum Six + Brushed

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

27 July 2015

Test Report No. R9080d

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: WK Marble & Granite Pty Ltd
Client Address: 129 Fairford Road

Padstow NSW 2211

Product Manufacturer: Supplied by WK Marble Marble & Granite Pty Ltd
Product Description: Quantum Six + Brushed

Test conducted according to: AS 4586:2013 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148
Conducted by: Clare Spinelli

Date: 23 July 2015 Temperature: 14°C
Sample: Unfixed Cleaning: None
Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed by wet lapping film
Slope of specimen: Tested on a flat level surface
Direction of Test: NA

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	15	13	12	11	14

Reported SRV of Sample:	13
Class:	P1



Ryan Voorderhake
Laboratory/Field Technician